GRPMSPEC 9/29/93

SARATOGA COUNTY SEWER DISTRICT #1

STANDARD NOTES - GRINDER PUMP SYSTEMS

PRESSURE SEWER SYSTEM INSTALLATION NOTES

- 1. THE DEVELOPER SHALL BE RESPONSIBLE FOR CONSTRUCTION OF THE PROPOSED PRESSURE SEWER SYSTEM AS SHOWN ON THESE PLANS.
- 2. ALL VALVE BOXES ARE TO BE BROUGHT TO GRADE.
- 3. ALL TEES AND BENDS TO HAVE A SOLID CONCRETE BLOCK (4" X 8' X 12") FOR THRUST RESTRAINT.
- 4. SUBMIT SHOP DRAWINGS AND/OR MATERIAL CERTIFICATION DOCUMENTATION TO THE SARATOGA COUNTY SEWER DISTRICT #1 (SCSD) FOR APPROVAL PRIOR TO CONSTRUCTION.
- 5. PIPE LINE SHALL BE TESTED AT 120 P.S.I.G. FOR A DURATION OF TWO HOURS. ALLOWABLE LEAKAGE FOR 1,000 L.F. OF PIPE SHALL BE AS FOLLOWS:

ALLOWABLE LEAKAGE
(GALLONS PER HOUR)
0.14
0.16
0.19
0.24

- PROPOSED PRESSURE SEWER SYSTEM SHALL BE CONSTRUCTED AND TESTED IN ACCORDANCE WITH THE REQUIREMENTS OF THE NEW YORK STATE DEPARTMENT OF ENVIRONMENTAL CONSERVATION AND THE SARATOGA COUNTY SEWER DISTRICT #1. A REPRESENTATIVE FROM THE SARATOGA COUNTY SEWER DISTRICT #1 SHALL WITNESS THE TEST.
- 7. COMPLETED PRESSURE SYSTEM SHALL BE DEDICATED TO THE SARATOGA COUNTY SEWER DISTRICT #1 FOR OPERATION AND MAINTENANCE.
- S. "AS-BUILT" MYLARS, CERTIFIED BY A NEW YORK STATE LICENSED SUR-VEYOR SHALL BE SUBMITTED TO THE DISTRICT SHOWING HORIZONTAL AND VERTICAL INFORMATION OF BOTH THE SEWER AND WATER SYSTEMS IN-STALLED.

GRINDER PUMP INSTALLATION NOTES

- 1. GRINDER PUMP ON EACH LOT SHALL BE CONSTRUCTED AT A TIME OF ACTUAL HOUSE CONSTRUCTION.
- LOCATION AND CONSTRUCTION OF GRINDER PUMPS SHALL BE APPROVED BY THE SARATOGA COUNTY SEWER DISTRICT #1 PRIOR TO APPLICATION FOR A BUILDING PERMIT. A PLOT PLAN OF THE LOT SHALL BE SUBMITTED TO THE SCSD FOR REVIEW.

GENERAL GUIDELINES:

- GRINDER PUMP SHALL BE LOCATED 20 MINIMUM FROM PROPOSED HOUSE.
- GRINDER FUMP SHALL BE LOCATED 20' MAXIMUM FROM PRCPOSED DRIVEWAY.
- HOUSE SERVICE CONNECTION TO GRINDER PUMP SHALLING BY GRAVITY LINE ONLY.